

Fire Alarm and Life Safety System Inspection Report

Your Facility
1 Toronto Street
Toronto, Ontario

Tested to ULC-S536 Standards

This Inspection was performed in accordance with applicable ULC Standards. The subsequent pages of this report provide performance measurements, listed ranges of acceptable results, and complete documentation of the inspection. Whenever discrepancies exist between acceptable performance standards and actual test results, notes and/or recommended solutions have been proposed or provided for immediate review and approval.

*Inspection Date
May 16, 2011*

Building: Your Facility
Contact: Ronald Macdonald
Title: Building Manager

Company: Steadfast Safety Services
Contact: Steven Kiss
Title: Fire Alarm technician





Executive Summary

Generated by: *BuildingReports.ca*

Building Information								
Building: Your Facility					Contact: Ronald Macdonald			
Address: 1 Toronto Street					Phone: Your phone number			
Address:					Fax: Your fax number			
City/Province/Postal Code: Toronto, Ontario M5R-1E8					Mobile:			
Country: Canada					Email:			
Inspection Performed By								
Company: Steadfast Safety Services					Inspector: Steven Kiss			
Address: 13 - 595 Middlefield Road					Phone: 416-332-0030			
Address:					Fax:			
City/Province/Postal Code: Toronto, ON M1V 3S2					Mobile: 416-678-9276			
Country: Canada					Email: stevekiss@steadfastsafety.com			
Monitoring								
Type: DVACS				Mfg: Europlex				Model #: 3008
Test Time/Date: 8:00 am 16 May 2011				Restore Time: 5:00 pm 17 May 2011				
Inspection Summary								
Category	Total Items		Serviced		Passed		Failed/Other	
	Qty	%	Qty	%	Qty	%	Qty	%
Supervisory	9	9.68%	9	100.00%	8	88.89%	1	11.11%
Monitor	2	2.15%	2	100.00%	2	100.00%	0	0%
Indicating	12	12.90%	12	100.00%	12	100.00%	0	0%
Initiating	64	68.82%	64	100.00%	60	93.75%	4	6.25%
Alarm	1	1.08%	1	100.00%	1	100.00%	0	0%
Control	5	5.38%	5	100.00%	5	100.00%	0	0%
Totals	93	100%	93	100.00%	88	94.62%	5	5.38%
Certification								
Building: Your Facility					Company: Steadfast Safety Services			
Contact: Ronald Macdonald					Inspector: Steven Kiss			
Signed:					Signed:			

Discrepancy Report

Generated by: BuildingReports.ca

Building: Your Facility		Control Panel: 1 - Notifier 5000 W/CBC		
<p><i>The Discrepancy Report consolidates each discrepancy listed within the various Testing sections of your Inspection. Discrepancies are listed by Category, and grouped by device type. The description of the problem is provided and where appropriate, code references are listed for your convenience. Any item that was inspected that is listed on the Consumer Product Safety Commission's website and is subject to a recall by the manufacturer is included.</i></p>				
Device Type	Manufacturer	ModelNumber	Date	Qty
Items listed for Recall by Manufacturer				
No recalled items found during this inspection.				
 ScanID	 Location	 Problem	Address	 Reference
Initiating				
Heat Detector				
15080589	1st Inside Elevator shaft . Barcode on Doorframe	No Access	1-3 .	
15080603	2nd Southwest Pastors office Second floor Barcode on Device	Needs Relocating	1-12 .	CAN/ULC S536 5.7.3.1
15080561	3rd South Belfry Smoke top of south stair/Belfry in sanctuary Barcode on Conduit below	Failed Operation	1-8 .	CAN/ULC S536 5.7.3.1
Smoke Detector				
15080560	2nd South Stairwell 2nd level Smoke top of south stair/Belfry in sanctuary Barcode on Left doorframe	Unable to reach to test sens	1-8 .	
Supervisory				
End Of Line				
15080564	2nd North Stairwell 2nd level Smoke top of North Stairs sanctuary Barcode on Device	Unable to locate	1-9 .	

Proposed Solutions Report

Generated by: BuildingReports.ca

Building: Your Facility		Control Panel: 1			
<p><i>The Proposed Solution Report provides a solution for each discrepancy listed on the Discrepancy Report. Provide a check mark where indicated to approve repairs listed within the report. Items listed as T/M are available for repair on a Time and Materials basis.</i></p>					
🔍 ScanID	📍 Location	🔧 Solution	Model #	Cost	Fix
<i>Initiating</i>					
Heat Detector					
15080589	1st Inside Elevator shaft . Barcode on Doorframe	Schedule elevator company	CR-135	T/M	<input type="checkbox"/>
15080603	2nd Southwest Pastors office Second floor Barcode on Device	Relocate with electrician	CR-135	T/M	<input type="checkbox"/>
15080561	3rd South Belfry Smoke top of south stair/Belfry in sanctuary Barcode on Conduit below	Replace smoke detector	CR-135	T/M	<input type="checkbox"/>
Smoke Detector					
15080560	2nd South Stairwell 2nd level Smoke top of south stair/Belfry in sanctuary Barcode on Left doorframe	Replace		T/M	<input type="checkbox"/>
<i>Supervisory</i>					
End Of Line					
15080564	2nd North Stairwell 2nd level Smoke top of North Stairs sanctuary Barcode on Device	Locate and test	.	T/M	<input type="checkbox"/>

Notes & Recommendations

Generated by: BuildingReports.ca

Building: Your Facility			Control Panel: 1	
<p><i>The Notes & Recommendations Report details additional inspection notes made by the Inspectors during the course of the building inspection. Notes are grouped by Category.</i></p>				
ScanID	Note	Device Type	Location	Comment
<i>Alarm</i>				
15080572	1	Kitchen Hood	1st West Kitchen Suppression System Kitchen Co2 system Barcode on device	Passed
Not labelled properly, should describe as Kitchen Suppression system				
<i>Initiating</i>				
15080589	2	Heat Detector	1st Inside Elevator shaft . Barcode on Doorframe	No Access
The client must schedule their elevator company to attend at same time as we do to test devices within the elevator shaft				
15080559	3	Pull Station	1st Southeast Sanctuary Main Exit Sanctuary area Barcode on device	Passed
.				
15080603	4	Heat Detector	2nd Southwest Pastors office Second floor Barcode on Device	Needs Relocating
Ducting has been installed over heat detector-Device must be relocated, requires electrician.				
15080561	5	Heat Detector	3rd South Belfry Smoke top of south stair/Belfry in sanctuary Barcode on Conduit below	Failed Operation
12 Ft A frame ladder required To Access				
<i>Supervisory</i>				
15080573	6	End Of Line	1st West Kitchen Suppression System Kitchen Co2 system Barcode on device	Passed
Not labelled properly, should describe as Kitchen Suppression system				
15080564	7	End Of Line	2nd North Stairwell 2nd level Smoke top of North Stairs sanctuary Barcode on Device	Unable to locate
Unable to locate this end of line resistor, investogate and replace.				

Individual Device Record

Generated by: BuildingReports.ca

Type of Inspection: Fire Alarm System Annual Inspection and Test (ULC S536)

Project Name: Your Facility

Inspection Date and Time: 5/16/11 4:02:50 PM

Inspector: Steven Kiss

Note: Reading Column: Detector sensitivity in percentage and Waterflow Switch time delay in seconds.

Building: Your Facility									
<p><i>The Individual Device Record lists each device type, it's exact location within the building, the corresponding zone or address of the device, and confirmation checkboxes indicating satisfactory test results for each ULC test requirement. Devices that are in need of service and repair are clearly indicated.</i></p>									
Location	Device Type	Zone/Address	Reading	Correctly Installed	Requires Service or Repairs	Alarm Operation Confirmed	Annunciation Indication Confirmed	Supervision	Ground Circuit Confirmed
Basement Inside FACP . Barcode on device	Battery	1		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
Basement West At bottom of stair entrance FACP Barcode on device	Control Panel	1		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
Basement West Electrical Area FACP Main Disconnect Barcode on device	Disconnect	1-Panel AA Breaker 42		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
Basement West Electrical Area Barcode on device	End Of Line	1-1 .		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
Basement West Electrical Area Barcode on device	Heat Detector	1-1 .		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Basement North Large Storage room Barcode on inner doorframe	Heat Detector	1-1 .		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Basement South Top of stairs to basement Barcode on device	Heat Detector	1-1 .		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Basement West Elevator Mech Room Boiler room Barcode on device	Heat Detector	1-5 .		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Basement West Boiler room Boiler room Barcode on device	Heat Detector	1-5 .		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Basement Northeast Area Basement Barcode on device	Horn	1-1 .		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Basement West Boiler room Boiler room Barcode on device	Horn/Strobe	1-.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Basement Inside FACP . Barcode on device	Monitoring	1		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Basement Inside FACP . Barcode on device	Monitoring	1		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Basement West Exit to stair Basement Barcode on device	Pull Station	1-1 .		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Basement North Exit to.Rear parking Basement Barcode on device	Pull Station	1-1 .		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Basement Northwest Stairwell to 1st floor Basement Barcode on device	Smoke Detector	1-1 .		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1st South Main Entrance Ground Floor Barcode on device	Annunciator	1-.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
1st Inside Main Office Area . Barcode on device	Annunciator	1-.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>

1st West Kitchen Suppression System Kitchen Co2 system Barcode on device	End Of Line	1-16 .	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
1st Northwest Recreation hall Recreation hall Barcode on device	End Of Line	1-4 .	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
1st West Kitchen Area Prep area Kitchen Barcode on device	Heat Detector	1-14 .	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1st West Kitchen Area Cooking area Kitchen Barcode on device	Heat Detector	1-14 .	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1st Inside Main Office Lunch room Ground floor Barcode on device	Heat Detector	1-3 .	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1st Northwest Large Storage closet Ground floor Barcode on device	Heat Detector	1-3 .	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1st West janitors supply room Ground floor Barcode on device	Heat Detector	1-3 .	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1st Southwest Kids Club room West Side Ground floor Barcode on Ceiling	Heat Detector	1-3 .	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1st Southwest Kids Club room East Side Ground floor Barcode on Ceiling	Heat Detector	1-3 .	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1st Southwest Kids Club room West Closet Ground floor Barcode on inner doorframe	Heat Detector	1-3 .	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1st Southwest Kids Club room East Closet Ground floor Barcode on inner doorframe	Heat Detector	1-3 .	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1st Southeast Library West side Ground floor Barcode on Device	Heat Detector	1-3 .	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1st Southeast Library East side Ground floor Barcode on Device	Heat Detector	1-3 .	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1st Inside Elevator shaft . Barcode on Doorframe	Heat Detector	1-3 .	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1st Northwest Recreation hall East side Recreation hall Barcode on device	Heat Detector	1-4 .	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1st Northwest Recreation hall Centre Recreation hall Barcode on device	Heat Detector	1-4 .	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1st Northwest Recreation hall West side Recreation hall Barcode on device	Heat Detector	1-4 .	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1st Southeast Sanctuary by Entrance Sanctuary area Barcode on device	Heat Detector	1-7 .	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1st Northeast Sanctuary by Entrance Sanctuary area Barcode on device	Heat Detector	1-7 .	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1st South Hall above entrance to Boiler/Machine room . Barcode on device	Horn	1-.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1st North Hall By Elevator . Barcode on device	Horn	1-.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1st West Rear Hall By washrooms . Barcode on device	Horn	1-.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1st Northwest Recreation hall . Barcode on device	Horn	1-.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1st West Kitchen Suppression System Kitchen Co2 system Barcode on device	Kitchen Hood	1-16 .	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1st South Main Entrance Ground Floor Barcode on device	Pull Station	1-3 .	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

1st North Rear office hall exit to rear parking Ground floor Barcode on device	Pull Station	1-3 .	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1st Northwest Hall west Exit by Bathrooms Ground floor Barcode on device	Pull Station	1-3 .	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1st Southwest Kids Club room. S/W Exit Ground floor Barcode on Device	Pull Station	1-3 .	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1st Northwest Recreation hall N/W Exit Recreation hall Barcode on device	Pull Station	1-4 .	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1st Northeast Sanctuary Main Exit Sanctuary area Barcode on device	Pull Station	1-7 .	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1st Southeast Sanctuary Main Exit Sanctuary area Barcode on device	Pull Station	1-7 .	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2nd Inside . Baptistry Exit to stairwell Third floor upper and lower Barcode on Device	End Of Line	1-11 .	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
2nd West Foyer top of Stairwell Second floor Barcode on Device	End Of Line	1-12 .	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
2nd North Stairwell 2nd level Smoke top of North Stairs sanctuary Barcode o Device	End Of Line	1-9 .	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2nd Northeast Theatre Behind stage Theatre Barcode on inside doorframe	Heat Detector	1-11 .	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2nd Northwest Theatre Behind stage Theatre Barcode on inside doorframe	Heat Detector	1-11 .	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2nd Inside . Baptistry Robing Room Third floor upper and lower Barcode on Device	Heat Detector	1-11 .	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2nd Inside Box office Second floor Barcode on inside doorframe	Heat Detector	1-12 .	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2nd Southwest Meeting room #3 Second floor Barcode on Device	Heat Detector	1-12 .	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2nd Southwest Meeting room #2 Second floor Barcode on Device	Heat Detector	1-12 .	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2nd Southwest Pastors office Second floor Barcode on Device	Heat Detector	1-12 .	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2nd North Sanctuary . Barcode on Device	Horn	1- .	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2nd West Foyer beside elevator Barcode on Device	Horn	1- .	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2nd Southwest Foyer outside Box office Barcode on Device	Horn	1- .	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2nd Southeast Hall outside Meeting room#2 Barcode on Device	Horn	1- .	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2nd South Outside Baptistry . Barcode on Device	Horn	1- .	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2nd North Theatre Emergency Exit Theatre Barcode on Device	Pull Station	1-11 .	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2nd Inside . Baptistry Exit to stairwell Third floor upper and lower Barcode on Device	Pull Station	1-11 .	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2nd West Foyer Exit to stairwell	Pull Station	1-12 .	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Second floor Barcode on Device									
2nd Southwest Hall Exit Second floor Barcode on Device	Pull Station	1-12 .		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2nd West Foyer Top of stairwell Second floor Barcode on Device	Smoke Detector	1-12 .	1.43	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2nd West Stairs Smoke west stair church hall Barcode on Device	Smoke Detector	1-2 .	2.6	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2nd Inside . Baptistry Sanctuary Barcode on Device	Smoke Detector	1-7 .	1.60	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2nd South Stairwell 2nd level Smoke top of south stair/Belfry in sanctuary Barcode on Left doorframe	Smoke Detector	1-8 .		<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2nd North Stairwell 2nd level Smoke top of North Stairs sanctuary Barcode on Device	Smoke Detector	1-9 .	2.4	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3rd Northwest Theatre upper hall Theatre Barcode on Device	End Of Line	1-11 .		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
3rd South Belfry Smoke top of south stair/Belfry in sanctuary Barcode on device	End Of Line	1-8 .		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
3rd Northwest Change room Third Floor upper and lower Barcode on Device	Heat Detector	1-10 .		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3rd Northeast Change room Third Floor upper and lower Barcode on Device	Heat Detector	1-10 .		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3rd South Clothing store W-Closet Third Floor upper and lower Barcode on Device	Heat Detector	1-10 .		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3rd South Clothing store S/W-Closet Third Floor upper and lower Barcode on Device	Heat Detector	1-10 .		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3rd South Clothing store E-Closet Third Floor upper and lower Barcode on Device	Heat Detector	1-10 .		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3rd South Clothing store S/ E-Closet Third Floor upper and lower Barcode on Device	Heat Detector	1-10 .		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3rd South Clothing store Kitchen Area Third Floor upper and lower Barcode on Device	Heat Detector	1-10 .		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3rd South Belfry Smoke top of south stair/Belfry in sanctuary Barcode on Conduit below	Heat Detector	1-8 .		<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3rd West Hall Exit To West Stair Third Floor upper and lower Barcode on Device	Horn	1-. .		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3rd West Hall Exit To West Stair Third Floor upper and lower Barcode on Device	Pull Station	1-10 .		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3rd Northwest Theatre upper hall Exit Theatre Barcode on Device	Pull Station	1-11 .		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Basement/Crawlspace West. Centrer	End Of Line	1-6 .		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>

West Crawl Space Barcode on device									
Basement/Crawlspace Southwest Crawlspace S/W Crawl Space Barcode on device	Heat Detector	1-6 .	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Basement/Crawlspace West Crawlspace West/Centre Crawl Space Barcode on device	Heat Detector	1-6 .	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Basement/Crawlspace Northwest Crawlspace N/W Crawl Space Barcode on device	Heat Detector	1-6 .	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Basement/Crawlspace Northeast Crawlspace North/East Crawl Space Barcode on device	Heat Detector	1-6 .	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Basement/Crawlspace East/Centre Crawlspace East/Centre Crawl Space Barcode on device	Heat Detector	1-6 .	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
Basement/Crawlspace South /East Crawlspace South/East Crawl Space Barcode on device	Heat Detector	1-6 .	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	

Inspection & Testing

Generated by: BuildingReports.ca

Building: Your Facility		Control Panel: 1		
<p><i>The Inspection & Testing section lists all of the items inspected in your building. Items are grouped by Passed or Failed/Other. Items are listed by Category. Each item includes the services performed, and the time & date at which testing occurred.</i></p>				
Device Type	Location	Service	Time	Date
<i>Passed</i>				
Alarm				
Kitchen Hood	1st West Kitchen Suppression System Kitchen Co2 system Barcode on device	Tested	1:38:13 PM	05/16/2011
Control				
Annunciator	1st South Main Entrance Ground Floor Barcode on device	Tested	12:03:37 PM	05/16/2011
Annunciator	1st Inside Main Office Area . Barcode on device	Tested	12:03:46 PM	05/16/2011
Battery	Basement Inside FACP . Barcode on device	Tested	12:01:57 PM	05/16/2011
Control Panel	Basement West At bottom of stair entrance FACP Barcode on device	Tested	12:01:51 PM	05/16/2011
Disconnect	Basement West Electrical Area FACP Main Disconnect Barcode on device	Tested	12:02:09 PM	05/16/2011
Indicating				
Horn	Basement Northeast Area Basement Barcode on device	Tested	12:02:44 PM	05/16/2011
Horn	1st South Hall above entrance to Boiler/Machine room . Barcode on device	Tested	1:05:17 PM	05/16/2011
Horn	1st North Hall By Elevator . Barcode on device	Tested	1:05:34 PM	05/16/2011
Horn	1st West Rear Hall By washrooms . Barcode on device	Tested	1:11:10 PM	05/16/2011
Horn	1st Northwest Recreation hall . Barcode on device	Tested	1:43:22 PM	05/16/2011
Horn	2nd North Sanctuary . Barcode on Device	Tested	12:59:24 PM	05/16/2011
Horn	2nd West Foyer beside elevator Barcode on Device	Tested	2:39:21 PM	05/16/2011
Horn	2nd Southwest Foyer outside Box office Barcode on Device	Tested	2:52:39 PM	05/16/2011
Horn	2nd Southeast Hall outside Meeting room#2 Barcode on Device	Tested	3:00:57 PM	05/16/2011
Horn	2nd South Outside Baptistry . Barcode on Device	Tested	3:54:52 PM	05/16/2011
Horn	3rd West Hall Exit To West Stair Third Floor upper and lower Barcode on Device	Tested	3:23:14 PM	05/16/2011
Horn/Strobe	Basement West Boiler room Boiler room Barcode on device	Tested	12:02:53 PM	05/16/2011
Initiating				
Heat Detector	Basement West Electrical Area Basement Barcode on device	Tested	12:02:13 PM	05/16/2011

Device Type	Location	Service	Time	Date
Heat Detector	Basement West Elevator Mech Room Boiler room Barcode on device	Tested	12:02:21 PM	05/16/2011
Heat Detector	Basement West Boiler room Boiler room Barcode on device	Bypassed	12:02:24 PM	05/16/2011
Heat Detector	Basement North Large Storage room Basement Barcode on inner doorframe	Tested	12:02:34 PM	05/16/2011
Heat Detector	Basement South Top of stairs to basement Barcode on device	Tested	12:02:57 PM	05/16/2011
Heat Detector	1st Inside Main Office Lunch room Ground floor Barcode on device	Tested	12:03:51 PM	05/16/2011
Heat Detector	1st Southeast Sanctuary by Entrance Sanctuary area Barcode on device	Tested	12:03:55 PM	05/16/2011
Heat Detector	1st Northeast Sanctuary by Entrance Sanctuary area Barcode on device	Tested	12:03:59 PM	05/16/2011
Heat Detector	1st Northwest Large Storage closet Ground floor Barcode on device	Tested	1:13:04 PM	05/16/2011
Heat Detector	1st West Kitchen Area Prep area Kitchen Barcode on device	Tested	1:16:19 PM	05/16/2011
Heat Detector	1st West Kitchen Area Cooking area Kitchen Barcode on device	Tested	1:29:45 PM	05/16/2011
Heat Detector	1st Northwest Recreation hall East side Recreation hall Barcode on device	Tested	1:50:11 PM	05/16/2011
Heat Detector	1st Northwest Recreation hall Centre Recreation hall Barcode on device	Tested	1:51:44 PM	05/16/2011
Heat Detector	1st Northwest Recreation hall West side Recreation hall Barcode on device	Tested	1:53:08 PM	05/16/2011
Heat Detector	1st West janitors supply room Ground floor Barcode on device	Tested	1:57:26 PM	05/16/2011
Heat Detector	1st Southwest Kids Club room West Side Ground floor Barcode on Ceiling	Tested	2:00:56 PM	05/16/2011
Heat Detector	1st Southwest Kids Club room East Side Ground floor Barcode on Ceiling	Tested	2:02:30 PM	05/16/2011
Heat Detector	1st Southwest Kids Club room West Closet Ground floor Barcode on inner doorframe	Tested	2:03:53 PM	05/16/2011
Heat Detector	1st Southwest Kids Club room East Closet Ground floor Barcode on inner doorframe	Tested	2:04:58 PM	05/16/2011
Heat Detector	1st Southeast Library West side Ground floor Barcode on Device	Tested	2:10:55 PM	05/16/2011
Heat Detector	1st Southeast Library East side Ground floor Barcode on Device	Tested	2:13:42 PM	05/16/2011
Heat Detector	2nd Northeast Theatre Behind stage Theatre Barcode on inside doorframe	Tested	2:41:01 PM	05/16/2011
Heat Detector	2nd Northwest Theatre Behind stage Theatre Barcode on inside doorframe	Tested	2:44:58 PM	05/16/2011
Heat Detector	2nd Inside Box office Second floor Barcode on inside doorframe	Tested	2:53:26 PM	05/16/2011
Heat Detector	2nd Southwest Meeting room #3 Second floor Barcode on Device	Tested	2:56:06 PM	05/16/2011
Heat Detector	2nd Southwest Meeting room #2 Second floor Barcode on Device	Tested	3:02:16 PM	05/16/2011
Heat Detector	2nd Inside . Baptistry Robing Room Third floor upper and lower Barcode on Device	Tested	3:58:20 PM	05/16/2011

Device Type	Location	Service	Time	Date
Heat Detector	3rd Northwest Change room Third Floor upper and lower Barcode on Device	Tested	3:27:29 PM	05/16/2011
Heat Detector	3rd Northeast Change room Third Floor upper and lower Barcode on Device	Tested	3:29:49 PM	05/16/2011
Heat Detector	3rd South Clothing store W-Closet Third Floor upper and lower Barcode on Device	Tested	3:32:53 PM	05/16/2011
Heat Detector	3rd South Clothing store S/W-Closet Third Floor upper and lower Barcode on Device	Tested	3:35:54 PM	05/16/2011
Heat Detector	3rd South Clothing store E-Closet Third Floor upper and lower Barcode on Device	Tested	3:38:42 PM	05/16/2011
Heat Detector	3rd South Clothing store S/ E-Closet Third Floor upper and lower Barcode on Device	Tested	3:41:07 PM	05/16/2011
Heat Detector	3rd South Clothing store Kitchen Area Third Floor upper and lower Barcode on Device	Tested	3:43:25 PM	05/16/2011
Heat Detector	Basement/Crawlspace Southwest Crawlspace S/W Crawl Space Barcode on device	Tested	12:03:08 PM	05/16/2011
Heat Detector	Basement/Crawlspace West Crawlspace West/Centre Crawl Space Barcode on device	Tested	12:03:12 PM	05/16/2011
Heat Detector	Basement/Crawlspace Northwest Crawlspace N/W Crawl Space Barcode on device	Tested	12:03:16 PM	05/16/2011
Heat Detector	Basement/Crawlspace Northeast Crawlspace North/East Crawl Space Barcode on device	Tested	12:03:20 PM	05/16/2011
Heat Detector	Basement/Crawlspace East/Centre Crawlspace East/Centre Crawl Space Barcode on device	Tested	12:03:23 PM	05/16/2011
Heat Detector	Basement/Crawlspace South /East Crawlspace South/East Crawl Space Barcode on device	Tested	12:03:29 PM	05/16/2011
Pull Station	Basement West Exit to stair Basement Barcode on device	Tested	12:02:29 PM	05/16/2011
Pull Station	Basement North Exit to.Rear parking Basement Barcode on device	Tested	12:02:40 PM	05/16/2011
Pull Station	1st South Main Entrance Ground Floor Barcode on device	Tested	12:03:33 PM	05/16/2011
Pull Station	1st Northeast Sanctuary Main Exit Sanctuary area Barcode on device	Tested	12:04:02 PM	05/16/2011
Pull Station	1st Southeast Sanctuary Main Exit Sanctuary area Barcode on device	Tested	12:04:06 PM	05/16/2011
Pull Station	1st North Rear office hall exit to rear parking Ground floor Barcode on device	Tested	1:08:04 PM	05/16/2011
Pull Station	1st Northwest Recreation hall N/W Exit Recreation hall Barcode on device	Tested	1:54:23 PM	05/16/2011
Pull Station	1st Northwest Hall west Exit by Bathrooms Ground floor Barcode on device	Tested	1:56:03 PM	05/16/2011
Pull Station	1st Southwest Kids Club room. S/W Exit Ground floor Barcode on Device	Tested	2:08:31 PM	05/16/2011
Pull Station	2nd West Foyer Exit to stairwell Second floor Barcode on Device	Tested	2:28:29 PM	05/16/2011
Pull Station	2nd North Theatre Emergency Exit Theatre Barcode on Device	Tested	2:47:46 PM	05/16/2011
Pull Station	2nd Southwest Hall Exit Second floor Barcode on Device	Tested	2:52:26 PM	05/16/2011
Pull Station	2nd Inside . Baptistry Exit to stairwell Third floor upper and lower Barcode on Device	Tested	4:01:52 PM	05/16/2011

Device Type	Location	Service	Time	Date
Pull Station	3rd West Hall Exit To West Stair Third Floor upper and lower Barcode on Device	Tested	3:21:37 PM	05/16/2011
Pull Station	3rd Northwest Theatre upper hall Exit Theatre Barcode on Device	Tested	3:50:31 PM	05/16/2011
Smoke Detector	Basement Northwest Stairwell to 1st floor Basement Barcode on device	Tested	12:02:50 PM	05/16/2011
Smoke Detector	2nd North Stairwell 2nd level Smoke top of North Stairs sanctuary Barcode on Device	Tested	12:56:33 PM	05/16/2011
Smoke Detector	2nd West Foyer Top of stairwell Second floor Barcode on Device	Tested	2:34:33 PM	05/16/2011
Smoke Detector	2nd West Stairs Smoke west stair church hall Barcode on Device	Tested	3:17:29 PM	05/16/2011
Smoke Detector	2nd Inside . Baptistry Sanctuary Barcode on Device	Tested	3:55:40 PM	05/16/2011
Monitor				
Monitoring	Basement Inside FACP . Barcode on device	Tested	12:02:02 PM	05/16/2011
Monitoring	Basement Inside FACP . Barcode on device	Tested	12:02:06 PM	05/16/2011
Supervisory				
End Of Line	Basement West Electrical Area Basement Barcode on device	Tested	12:02:17 PM	05/16/2011
End Of Line	1st West Kitchen Suppression System Kitchen Co2 system Barcode on device	Tested	1:34:47 PM	05/16/2011
End Of Line	1st Northwest Recreation hall Recreation hall Barcode on device	Tested	1:46:17 PM	05/16/2011
End Of Line	2nd West Foyer top of Stairwell Second floor Barcode on Device	Tested	2:33:58 PM	05/16/2011
End Of Line	2nd Inside . Baptistry Exit to stairwell Third floor upper and lower Barcode on Device	Tested	4:02:50 PM	05/16/2011
End Of Line	3rd South Belfry Smoke top of south stair/Belfry in sanctuary Barcode on device	Tested	12:25:57 PM	05/16/2011
End Of Line	3rd Northwest Theatre upper hall Theatre Barcode on Device	Tested	3:46:44 PM	05/16/2011
End Of Line	Basement/Crawlspace West. Centrer West Crawl Space Barcode on device	Tested	12:03:02 PM	05/16/2011
<i>Failed/Other</i>				
Initiating				
Heat Detector	1st Inside Elevator shaft . Barcode on Doorframe	Bypassed	2:24:58 PM	05/16/2011
Heat Detector	2nd Southwest Pastors office Second floor Barcode on Device	Tested	3:14:01 PM	05/16/2011
Heat Detector	3rd South Belfry Smoke top of south stair/Belfry in sanctuary Barcode on Conduit below	Tested	12:20:11 PM	05/16/2011
Smoke Detector	2nd South Stairwell 2nd level Smoke top of south stair/Belfry in sanctuary Barcode on Left doorframe	Tested	12:31:34 PM	05/16/2011
Supervisory				
End Of Line	2nd North Stairwell 2nd level Smoke top of North Stairs sanctuary Barcode on Device	Visually Checked	12:58:06 PM	05/16/2011

Sensitivity Testing

Generated by: BuildingReports.ca

Building: Your Facility				Control Panel: 1	
<p><i>The Sensitivity Testing section details the sensitivity test ranges and acceptable readings for each type of device. Items are grouped by Passed or Failed/Other. Normally, Devices that perform outside the acceptable range of sensitivity are listed in Failed/Other.</i></p>					
Location	Address	Model #	Range	%	ScanID
<i>Passed</i>					
Smoke Detector					
2nd North Stairwell 2nd level Smoke top of North Stairs sanctuary Barcode on Device	1-9 .	C2W-BA		2.4	15080563
2nd West Foyer Top of stairwell Second floor Barcode on Device	1-12 .	MIR-1400A		1.43	15080591
2nd West Stairs Smoke west stair church hall Barcode on Device	1-2 .	C2W-BA		2.6	15080604
2nd Inside . Baptistry Sanctuary Barcode on Device	1-7 .	MIR-1400		1.60	15080617

Battery & Power Supply Testing

Generated by: BuildingReports.ca

Building: Your Facility			Control Panel: 1			
<p><i>The Control & Power Testing section details the readings and measurements of batteries and power supplies used to provide power to the fire alarm and life safety systems. Items are grouped by Passed or Failed/Other.</i></p>						
Type	Location	Comment	Amps	Volts	Pre Test	Post Test
<i>Passed</i>						
Battery						
Sealed Lead Acid	Basement Inside FACP . Barcode on device	Passed	18	12		
Control Panel						
	Basement West At bottom of stair entrance FACP Barcode on device	Passed				

Inventory & Warranty Report

Generated by: BuildingReports.ca

Building: Your Facility		Control Panel: 1		
<p><i>The Inventory & Warranty Report lists each of the devices and items that are included in your Inspection Report. A complete inventory count by device type and category is provided. Items installed within the last 90 days, within the last year, and devices installed for two years or more are grouped together for easy reference.</i></p>				
Device or Item	Category	% of Inventory	Quantity	
Control Panel	Control	1.08%	1	
Battery	Control	1.08%	1	
Monitoring	Monitor	2.15%	2	
Disconnect	Control	1.08%	1	
Heat Detector	Initiating	46.24%	43	
End Of Line	Supervisory	9.68%	9	
Pull Station	Initiating	16.13%	15	
Horn	Indicating	11.83%	11	
Smoke Detector	Initiating	6.45%	6	
Horn/Strobe	Indicating	1.08%	1	
Annunciator	Control	2.15%	2	
Kitchen Hood	Alarm	1.08%	1	
Type	Qty	Model #	Description	Install Date
<i>New (under 90 days)</i>				
.				
Monitoring	1	.	Alarm	04/01/2011
Monitoring	1	.	Trouble	04/01/2011
Federal/Pioneer				
Disconnect	1	NBDP424-3L1	Breaker	04/01/2011
Ideal Power				
Battery	1	ELA-12-18AH.	Sealed Lead Acid	04/01/2011
<i>In Service - 10 Years to 15 Years</i>				
Edwards				
Heat Detector	2	281c	Rate-of-Rise	11/17/1996
Pull Station	1	270-SPO	Single Action	11/17/1996
Mircom				
End Of Line	1	.		11/17/1996
End Of Line	6	3.9 kohm		11/17/1996
End Of Line	1	3.9Kohm		11/17/1996
End Of Line	1	MIR-1400A		11/17/1996
Horn/Strobe	1	FHS/240R		11/17/1996
Pull Station	1	MPS-950b	Single Action	11/17/1996
Pull Station	1	MS-401	Single Action	11/17/1996
Smoke Detector	1	MIR-1400A	Ionization	11/17/1996
Notifier				
Annunciator	2	.	LED List	11/17/1996
Horn	2	MPS-950b		11/17/1996

Pull Station	3	MPS-950	Single Action	11/17/1996
Pull Station	9	MPS-950b	Single Action	11/17/1996
Range Guard				
Kitchen Hood	1	RG-2.5g	Wet	11/17/1996
System Sensor				
Heat Detector	3	CF-200	Fixed Temperature	11/17/1996
Heat Detector	38	CR-135	Rate-of-Rise	11/17/1996
Smoke Detector	1		Photoelectric	11/17/1996
Smoke Detector	3	C2W-BA	Photoelectric	11/17/1996
Smoke Detector	1	MIR-1400	Photoelectric	11/17/1996
Wheelock				
Horn	8	MT-12-24		11/17/1996
Horn	1	MT-12/24		11/17/1996
<i>In Service - 15 Years to 25 Years</i>				
Notifier				
Control Panel	1	5000 W/CBC		05/17/1996

Zone Address Report

Generated by: BuildingReports.ca

Building: Your Facility		Control Panel: 1		
<p><i>The Zone Address Report lists all of the devices and items that have an individual address, or are grouped together under a common zone. The device type, location, and description are included for your reference.</i></p>				
Address	Device Type	Location	Description	ScanID
.	Horn/Strobe	Basement West Boiler room	Boiler room	15080542
.	Annunciator	Barcode on device		
.	Annunciator	1st Inside Main Office Area	. Barcode on device	LED List 15080554
.	Annunciator	1st South Main Entrance	Ground Floor	LED List 15080552
.	Horn	Barcode on device		
.	Horn	1st South Hall	above entrance to	15080553
.	Horn	Boiler/Machine room	. Barcode on device	
.	Horn	1st North Hall	By Elevator . Barcode on device	15080566
.	Horn	1st West Rear Hall	By washrooms . Barcode on device	15080568
.	Horn	1st Northwest Recreation hall	. Barcode on device	15080574
.	Horn	2nd North Sanctuary	. Barcode on Device	15080565
Zone/Circuit: .				
.	Horn	2nd West Foyer	beside elevator Barcode on Device	15080593
.	Horn	2nd Southwest Foyer	outside Box office Barcode on Device	15080597
.	Horn	2nd Southeast Hall	outside Meeting room#2 Barcode on Device	15080601
.	Horn	2nd South Outside	Baptistry . Barcode on Device	15080616
.	Horn	3rd West Hall	Exit To West Stair Third Floor upper and lower Barcode on Device	15080606
Zone/Circuit: 1				
.	End Of Line	Basement West Electrical	Area Barcode on device	15080534
.	Heat Detector	Basement West Electrical	Area Barcode on device	Rate-of-Rise 15080533
.	Heat Detector	Basement North Large	Storage room Barcode on inner doorframe	Rate-of-Rise 15080538
.	Heat Detector	Basement South	Top of stairs to basement Barcode on device	Rate-of-Rise 15080543
.	Horn	Basement Northeast	Area Barcode on device	15080540
.	Pull Station	Basement North	Exit to.Rear parking Barcode on device	Single Action 15080539
.	Pull Station	Basement West	Exit to stair Barcode on device	Single Action 15080537

.	Smoke Detector	Basement Northwest Stairwell to 1st floor Basement Barcode on device	Photoelectric	15080541
Zone/Circuit: 10				
.	Heat Detector	3rd Northwest Change room Third Floor upper and lower Barcode on Device	Rate-of-Rise	15080607
.	Heat Detector	3rd Northeast Change room Third Floor upper and lower Barcode on Device	Rate-of-Rise	15080608
.	Heat Detector	3rd South Clothing store W-Closet Third Floor upper and lower Barcode on Device	Rate-of-Rise	15080609
.	Heat Detector	3rd South Clothing store S/W-Closet Third Floor upper and lower Barcode on Device	Rate-of-Rise	15080610
.	Heat Detector	3rd South Clothing store E-Closet Third Floor upper and lower Barcode on Device	Rate-of-Rise	15080611
.	Heat Detector	3rd South Clothing store S/ E-Closet Third Floor upper and lower Barcode on Device	Rate-of-Rise	15080612
.	Heat Detector	3rd South Clothing store Kitchen Area Third Floor upper and lower Barcode on Device	Rate-of-Rise	15080613
.	Pull Station	3rd West Hall Exit To West Stair Third Floor upper and lower Barcode on Device	Single Action	15080605
Zone/Circuit: 11				
.	End Of Line	2nd Inside . Baptistry Exit to stairwell Third floor upper and lower Barcode on Device		15080620
.	Heat Detector	2nd Inside . Baptistry Robing Room Third floor upper and lower Barcode on Device	Rate-of-Rise	15080618
.	Heat Detector	2nd Northeast Theatre Behind stage Theatre Barcode on inside doorframe	Rate-of-Rise	15080594
.	Heat Detector	2nd Northwest Theatre Behind stage Theatre Barcode on inside doorframe	Rate-of-Rise	15080595
.	Pull Station	2nd North Theatre Emergency Exit Theatre Barcode on Device	Single Action	15080596
.	Pull Station	2nd Inside . Baptistry Exit to stairwell Third floor upper and lower Barcode on Device	Single Action	15080619
.	End Of Line	3rd Northwest Theatre upper hall Theatre Barcode on Device		15080614
.	Pull Station	3rd Northwest Theatre upper hall Exit Theatre Barcode on Device	Single Action	15080615
Zone/Circuit: 12				
.	End Of Line	2nd West Foyer top of Stairwell Second floor Barcode on Device		15080592
.	Heat Detector	2nd Southwest Meeting room #2 Second floor Barcode on Device	Rate-of-Rise	15080602
.	Heat Detector	2nd Southwest Pastors office Second floor Barcode on Device	Rate-of-Rise	15080603
.	Heat Detector	2nd Inside Box officel Second floor Barcode on inside doorframe	Rate-of-Rise	15080599
.	Heat Detector	2nd Southwest Meeting room #3 Second floor Barcode on inside doorframe	Rate-of-Rise	15080600

.	Pull Station	floor Barcode on Device 2nd Southwest Hall Exit Second floor	Single Action	15080598
.	Pull Station	Barcode on Device 2nd West Foyer Exit to stairwell Second floor Barcode on Device	Single Action	15080590
.	Smoke Detector	2nd West Foyer Top of stairwell Second floor Barcode on Device	Ionization	15080591
Zone/Circuit: 14				
.	Heat Detector	1st West Kitchen Area Prep area Kitchen Barcode on device	Fixed Temperature	15080570
.	Heat Detector	1st West Kitchen Area Cooking area Kitchen Barcode on device	Fixed Temperature	15080571
Zone/Circuit: 16				
.	End Of Line	1st West Kitchen Suppression System Kitchen Co2 system Barcode on device		15080573
.	Kitchen Hood	1st West Kitchen Suppression System Kitchen Co2 system Barcode on device	Wet	15080572
Zone/Circuit: 2				
.	Smoke Detector	2nd West Stairs Smoke west stair church hall Barcode on Device	Photoelectric	15080604
Zone/Circuit: 3				
.	Heat Detector	1st Southeast Library West side Ground floor Barcode on Device	Rate-of-Rise	15080587
.	Heat Detector	1st Southeast Library East side Ground floor Barcode on Device	Rate-of-Rise	15080588
.	Heat Detector	1st Inside Elevator shaft . Barcode on Doorframe	Rate-of-Rise	15080589
.	Heat Detector	1st West janitors supply room Ground floor Barcode on device	Rate-of-Rise	15080581
.	Heat Detector	1st Southwest Kids Club room West Side Ground floor Barcode on Ceiling	Rate-of-Rise	15080582
.	Heat Detector	1st Southwest Kids Club room East Side Ground floor Barcode on Ceiling	Rate-of-Rise	15080583
.	Heat Detector	1st Southwest Kids Club room West Closet Ground floor Barcode on inner doorframe	Rate-of-Rise	15080584
.	Heat Detector	1st Southwest Kids Club room East Closet Ground floor Barcode on inner doorframe	Rate-of-Rise	15080585
.	Heat Detector	1st Northwest Large Storage closet Ground floor Barcode on device	Rate-of-Rise	15080569
.	Heat Detector	1st Inside Main Office Lonch room Ground floor Barcode on device	Rate-of-Rise	15080555
.	Pull Station	1st South Main Entrance Ground Floor Barcode on device	Single Action	15080551
.	Pull Station	1st North Rear office hall exit to rear parking Ground floor Barcode on device	Single Action	15080567
.	Pull Station	1st Southwest Kids Club room. S/W Exit Ground floor Barcode on Device	Single Action	15080586
.	Pull Station	1st Northwest Hall west Exit by Bathrooms Ground floor Barcode on	Single Action	15080580

device

Zone/Circuit: 4

.	End Of Line	1st Northwest Recreation hall Recreation hall Barcode on device		15080575
.	Heat Detector	1st Northwest Recreation hall East side Recreation hall Barcode on device	Rate-of-Rise	15080576
.	Heat Detector	1st Northwest Recreation hall Centre Recreation hall Barcode on device	Rate-of-Rise	15080577
.	Heat Detector	1st Northwest Recreation hall West side Recreation hall Barcode on device	Rate-of-Rise	15080578
.	Pull Station	1st Northwest Recreation hall N/W Exit Recreation hall Barcode on device	Single Action	15080579

Zone/Circuit: 5

.	Heat Detector	Basement West Elevator Mech Room Boiler room Barcode on device	Rate-of-Rise	15080535
.	Heat Detector	Basement West Boiler room Boiler room Barcode on device	Fixed Temperature	15080536

Zone/Circuit: 6

.	End Of Line	Basement/Crawlspace West. Centrer West Crawl Space Barcode on device		15080544
.	Heat Detector	Basement/Crawlspace Southwest Crawlspace S/W Crawl Space Barcode on device	Rate-of-Rise	15080545
.	Heat Detector	Basement/Crawlspace West Crawlspace West/Centre Crawl Space Barcode on device	Rate-of-Rise	15080546
.	Heat Detector	Basement/Crawlspace Northwest Crawlspace N/W Crawl Space Barcode on device	Rate-of-Rise	15080547
.	Heat Detector	Basement/Crawlspace Northeast Crawlspace North/East Crawl Space Barcode on device	Rate-of-Rise	15080548
.	Heat Detector	Basement/Crawlspace East/Centre Crawlspace East/Centre Crawl Space Barcode on device	Rate-of-Rise	15080549
.	Heat Detector	Basement/Crawlspace South /East Crawlspace South/East Crawl Space Barcode on device	Rate-of-Rise	15080550

Zone/Circuit: 7

.	Heat Detector	1st Southeast Sanctuary by Entrance Sanctuary area Barcode on device	Rate-of-Rise	15080556
.	Heat Detector	1st Northeast Sanctuary by Entrance Sanctuary area Barcode on device	Rate-of-Rise	15080557
.	Pull Station	1st Northeast Sanctuary Main Exit Sanctuary area Barcode on device	Single Action	15080558
.	Pull Station	1st Southeast Sanctuary Main Exit Sanctuary area Barcode on device	Single Action	15080559
.	Smoke Detector	2nd Inside . Baptistry Sanctuary Barcode on Device	Photoelectric	15080617

Zone/Circuit: 8

.	Smoke Detector	2nd South Stairwell 2nd level Smoke top of south stair/Belfry in sanctuary Barcode on Left doorframe	Photoelectric	15080560
.	End Of Line	3rd South Belfry Smoke top of south stair/Belfry in sanctuary Barcode on device		15080562
.	Heat Detector	3rd South Belfry Smoke top of south stair/Belfry in sanctuary Barcode on Conduit below	Rate-of-Rise	15080561
Zone/Circuit: 9				
.	End Of Line	2nd North Stairwell 2nd level Smoke top of North Stairs sanctuary Barcode on Device		15080564
.	Smoke Detector	2nd North Stairwell 2nd level Smoke top of North Stairs sanctuary Barcode on Device	Photoelectric	15080563
Zone/Circuit: Panel AA				
Breaker 42	Disconnect	Basement West Electrical Area FACP Main Disconnect Barcode on device	Breaker	15080532